



17575 Peak Avenue  
Morgan Hill, CA 95037-4128  
TEL: (408) 778-6480  
FAX: (408) 779-7236  
[www.morganhill.ca.gov](http://www.morganhill.ca.gov)

---

## **ADDENDUM NO. 4**

**DATE:** January 12, 2024

**TO:** ALL PLANHOLDERS OF THE MADRONE CHANNEL TRAIL PHASE 2 PROJECT

**FROM:** KRISTIAN WALLACE – PROJECT ENGINEER

**RE:** TRAIL PAVEMENT CLARIFICATION

1. The trail pavement may be rolled as a single lift. If rolled as a single lift, 3/8-inch Type A asphalt should be used for the pavement section.

### ADDENDUM ACKNOWLEDGMENT

Bidder acknowledges receipt of this addendum, which shall be attached to the proposal.

---

Contractor's Representative

---

Date

**THIS DOCUMENT SHALL BECOME A PART OF THE PROJECT SPECIFICATIONS**