



CITY OF MORGAN HILL

17575 Peak Avenue
Morgan Hill, CA 95037-4128
TEL: (408) 778-6480
FAX: (408) 779-7236
www.morganhill.ca.gov

Addendum No. 4

DATE: April 28, 2025

TO: ALL PLANHOLDERS OF THE 2025 MORGAN HILL WATER MAIN
REPLACEMENT PROJECT

FROM: YAT CHO – PROJECT ENGINEER

RE: CLARIFICATIONS

1. Under D4 – WATER in the Technical Specifications, Replace 4.03 – EXISTING FACILITIES with the attached 4.03R – EXISITNG FACILITIES

ADDENDUM ACKNOWLEDGMENT

Bidder acknowledges receipt of this addendum, which shall be attached to the proposal.

Contractor's Representative

Date

THIS DOCUMENT SHALL BECOME A PART OF THE PROJECT SPECIFICATIONS

4.03R EXISTING FACILITIES

a. Description: The work performed in connection with various existing highway and utility facilities shall conform to the provisions in Section 15, "Existing Highway Facilities," of the Standard Specifications and these Technical Provisions.

The work involved in this section includes, but is not limited to the following: Abandon, removal and reconstruction of existing facilities, modification and removal of concrete structures, and protecting existing facilities to remain

1. **ABANDON EXISTING WATER MAIN** – This work shall consist of disconnecting and capping water lines at the locations shown on the plans, when no longer needed. The contractor shall remove existing water mains to be abandoned if they interfere with the new work. Contractor shall dispose of removed materials offsite in accordance with applicable regulations. Water mains abandoned in place shall be filled with slurry cement or controlled density fill (CDF) and capped in conformance with the provisions in Section 19-3.02, "Slurry Cement Backfill," of the Standard Specifications, the Engineering Drawings, and these Technical Provisions, except that aggregate shall be concrete sand.

Water mains to be abandoned shall remain in service until new mains have been installed, tested and placed into service and all domestic and fire services have been transferred. This work shall consist of abandoning existing water main in place, disconnecting and capping water lines at the locations shown on the plans, when no longer needed. The Contractor shall remove existing ACP water mains to be abandoned if they interfere with the new work. The contractor shall dispose of removed materials off site in accordance with applicable regulations.

2. **ABANDON EXISTING WATER VALVE AND REMOVE VALVE BOX** – This work shall consist of the removal of the existing water valve and valve box at the locations shown on the plans, when no longer needed. The ends of the abandoned water main, valve, and valve boxes shall be filled with slurry cement and capped.

- a. Submittals: Submit product data for slurry cement backfill.
- b. Measurement and Payment: The contract unit price paid for each Abandon Water Valve and Remove Valve Box under Bid Schedule I, Bid Item 7 and Bid Schedule II, Bid Item 7 and Abandon Existing Water Main under Bid Schedule I, Bid Item 8 and Bid Schedule II, Bid Item 8 shall be considered as included in the contract items of work involved, and no separate payment will be made therefore. All work involved to abandon water valve and remove valve box and to abandoning water main in place includes; slurry filling, demolition, and removal of existing valve and valve box, removing pipe and materials off site, as well as including all saw cutting, removal and restoration of all surfaces, trenches and appurtenances, disconnecting and protecting existing services and laterals, as shown in the plans, as specified in the Standard Specifications and these Technical Provisions, and as directed by the engineer. The cost of removing existing water that interfere with the construction of the Work

ADDENDUM No. 4

shall be considered as included in the contract items of work involved, and no separate payment will be made therefore.